



CSA INTERNATIONAL

# Certificate of Compliance

**Certificate:** 1781791

**Master Contract:** 159754

**Project:** 2142877

**Date Issued:** 2009/04/23

**Issued to:** Pepperl+Fuchs, Incorporated

1600 Enterprise Pky  
Twinsburg, OH 44087  
USA

**Attention:** Gregory Prosser

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Scott Wallace

**Authorized by:** Patricia Pasemko, Operations  
Manager

## **PRODUCTS**

**CLASS 3218 06** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus - For  
Hazardous Locations

**Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III**

Proximity Switche Cat No. 973EX4WI-A10T, input rated 20-250V ac or dc, 200mA max load.



**Certificate:** 1781791

**Master Contract:** 159754

**Project:** 2142877

**Date Issued:** 2009/04/23

---

Note: Unless a grounding lead is provided, this switch is Certified only for use with other equipment, where the suitability of the final combination is to be determined by CSA International or the Inspection Authority having jurisdiction.

### **APPLICABLE REQUIREMENTS**

- CSA C22.2 No. 0-M1982 - General Requirements - Canadian Electrical Code, Part II  
(Reaffirmed 2006)
- CSA C22.2 No 14-05 - Industrial Control Equipment  
(Approved March 2006)
- CSA C22.2 No 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations  
(Reaffirmed 2003)

### **MARKINGS**

Markings are chemically etched on the endcap of the finished assembly. See Dwg. 110-2063 for details.

- CSA Monogram
- Submitter Name or Identification: (Pepper + Fuchs Inc.)
- Model Number: (973EX4WI-A10T)
- Electrical Rating: (20-250 Volts AC/DC)
- Max. Load: (200mA)
- Hazardous Location Designation: (Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III)

Note - Jurisdictions in Canada may require these markings to also be provided in French language. It is the responsibility of the manufacturer to provide bilingual marking, where applicable, in accordance with the requirements of the Provincial Regulatory Authorities. It is the responsibility of the manufacturer to determine this requirement and have bilingual wording added to the "Markings".